

## CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: \_\_\_\_\_ Date of Visit: \_\_\_\_\_

Contractor Personnel on Site:

1. _____	3. _____
2. _____	4. _____

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**FILTER REPLACEMENT**

SITE AND BLDG #: VA701-01

MECHANIC  
SIGNATURE: 

DATE: 09-02-21

LOCATION/RM #:

WO# 14583

START TIME: 0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>						
1	Check, clean, and/or replace filters as required.	✓				
2	Initial and Date Filter (if disposable)	✓				
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓				
ASSET #	SIZE	QTY	NOTES/ ACTIONS			
Record Size :						
3Y173	20x20x2	12				
3Y174	20x24x2	6				
3Y175	12x24x2	4				
3Y176						
NOTE : Any AHU with outside air -Filter gets replaced Quarterly						
All other filters get replaced annually But inspected Quarterly						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

**Additional Notes:**