

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 Date of Visit: 09/15/21

Contractor Personnel on Site:

- | | |
|----------|----------|
| 1. _____ | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____


74

43

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 09/15/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Danielle Barrett Date: 09/15/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **FILTER REPLACEMENT**

SITE AND BLDG #: DE007 B-1

MECHANIC SIGNATURE:  **DATE:** 09/15/21

LOCATION/RM #: WO# 14844

START TIME: 0900 **FINISH TIME:** 1630

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS <small>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</small> |
|--|---|---------------|----|--|
| | | YES | NO | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Check, clean, and/or replace filters as required. | ✓ | | |
| 2 | Initial and Date Filter (if disposable) | ✓ | | |
| 3 | Initial and Date Yellow Maintenance Tag (if applicable) | ✓ | | |
| ASSET # | SIZE | QTY | | NOTES/ ACTIONS |
| 1743 | Record Size : | 1 | | |
| 1744 | | 1 | | |
| 1745 | | 1 | | |
| 1753 | | 1 | | |
| 1762 | washable filters | 2 | | |
| 1763 | | 2 | | |
| 1764 | | 2 | | |
| 1765 | | 2 | | |
| | | | | |
| | | | | |
| | NOTE : Any AHU with outside air -Filter gets replaced Quarterly | | | |
| | All other filters get replaced annually But inspected Quarterly | | | |
| | | | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: