

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: \_\_\_\_\_ Date of Visit: \_\_\_\_\_

Contractor Personnel on Site:

- |          |          |
|----------|----------|
| 1. _____ | 3. _____ |
| 2. _____ | 4. _____ |

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_

-----

**CERTIFICATION OF WORK**

To be signed by the Contractor:


Print Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: 

E-Mail: \_\_\_\_\_

# **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST** **EXPANSION TANKS**

SITE AND BLDG #: VA049-01      3Y233,3Y234  
3Y235  
LOCATION/RM #:      WO# 14973      ASSET #

MECHANIC SIGNATURE:       DATE: 09-21-21  
START TIME: 0900      FINISH TIME: 1630

| CHECK POINT                                | CHECKPOINT DESCRIPTION  | TASK COMPLETE |    | NOTES/ ACTIONS<br>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|--|---|---------------|----|---|
|  |   | YES           | NO |   |
| SPECIAL INSTRUCTIONS                       |   |               |    |   |
| 1  | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | ✓             |    |   |
| TO BE PERFORMED AT EACH INSPECTION SERVICE |   |               |    |   |
| 1  | Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.  | ✓             |    |   |
| 2  | If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.   | NA            |    |   |
| 3  | If applicable, check tank pressure via schrader valve. Correct as needed.   | ✓             |    |   |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**