

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 11/29/21

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 14978 , 14979 , 15146 -15149 , 15161 , 15165 , 15176 , 15186 ,
2. 15150 , 15151-15153
3. ASSET#'S , 9932 , 9935 , 9898 , 9929 , 9933 , 9934 , 9890 , 9940 ,
4. 9941 , 9946 , 9947 , 190917- , 269 , 250 , 251 , 263 , 268 , 265 , 266
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 11/29/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT STORMS Date: 11/29/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CIRCULATING AND BOOSTER PUMPS

SITE AND BLDG #: NY039 BLDG1

AHU ROOM

LOCATION/RM #: WO# 15146 ASSET # 9898

MECHANIC
SIGNATURE: 

DATE: 11/29/21

START TIME: 8am

FINISH TIME: 8:30am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓	/	
2	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.-Report any leaks	✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication atleast annually.4 shots of grease per PM	✓	/	used Lucas heavy duty grease
2	Inspect couplings and check for any pump seal leaks.	✓	/	no leaks
3	Check motor mounts and vibration pads	✓	/	mounts and pads are good
4	Tighten all pump flanges.	✓	/	flanges are tight
5	Visually check pump alignment and coupling -Report unusual vibration	✓	/	alignment is good no vibration
6	Inspect electrical connections	✓	/	electrical connections are good

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

this pump has not run since the air handler has been down