

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 11/29/21

Contractor Personnel on Site:

- |                         |          |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____                | 4. _____ |

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 14978 , 14979 , 15146 -15149 , 15161 , 15165 , 15176 , 15186 ,
2. 15150 , 15151-15153
3. ASSET#'S , 9932 , 9935 , 9898 , 9929 , 9933 , 9934 , 9890 , 9940 ,
4. 9941 , 9946 , 9947 , 190917- , 269 , 250 , 251 , 263 , 268 , 265 , 266
5. \_\_\_\_\_

-----  
**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 11/29/21

Signed: 

To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT STORMS Date: 11/29/21

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**EMERGENCY EXIT SIGNS AND WALL PACKS**

ACTIVITY AND BLDG #: NY039 BLDG1 9933, MECHANIC SIGNATURE:  DATE: 11/29/21  
 LOCATION/RM #: BLDG1 WO# 15148, ASSET # 9934, START TIME: 9am FINISH TIME: 10am  
 15149, 190917-268

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	no structural defects
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	units function properly
3	Clean exterior with dry cloth.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	units have been wiped down
4	For Exit lights check for proper arrow direction.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Arrow directions are proper
5	Make and/or recommend any needed repairs.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

**Additional Notes:**