

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: _____ Date of Visit: _____

Contractor Personnel on Site:

- | | |
|----------|----------|
| 1. _____ | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: _____ Date: _____

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: VA701-01MECHANIC
SIGNATURE: DATE: 11-23-21LOCATION/RM #: WO# 15213START TIME: 0900FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Initial and Date Filter (if disposable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Initial and Date Yellow Maintenance Tag (if applicable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
3Y173	20x20x2	12		
3Y174	20x24x2	6		
3Y175	12x24x2	4		
3Y176				
	20x20x12	6		These are final filters that are replaced once a year
	20x24x12	6		
	12x24x12	4		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: