

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 12/8/21-12/13/21

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15219 , 15506 , 15534 , 15220 , 15495 , 15507 , 15535 ,
2. ASSET#'S , 190917- , 606-611 , 617 , 634 , 635 , 643 , 609 , 620 ,
3. 679-681 , 691 , 695 , 698 , 705 , 706 , 724 , 697 , 699 , 701 , 704-706 ,
4. 725 , 726 ,
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/13/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LARS LUFGMAN Date: 12/13/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: **NY127 BLDG2**MECHANIC
SIGNATURE: DATE: **12/8/21**LOCATION/RM #: **BLDG2** WO# **15220**START TIME: **10:30am**FINISH TIME: **11:30am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	✓	X	
2	Initial and Date Filter (if disposable)	✓	X	
3	Initial and Date Yellow Maintenance Tag (if applicable)	✓	X	
ASSET #	SIZE	QTY	NOTES/ ACTIONS	
	Record Size :			
190917-691	16x24x2	1		
190917-695	15x11- 3/8 x3/8 box filter	4-2	15x11 are washable	
190917-698	16x20x2 - 16x25x2 - 20x16x12	6-4-6		
190917-705	20x20x4	1		
190917-706	16x20x4	1		
NOTE : Any AHU with outside air -Filter gets replaced Quarterly				
All other filters get replaced annually But inspected Quarterly				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: