

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 Date of Visit: 11/22/21

Contractor Personnel on Site:

1. _____	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 11/22/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Danielle Barrett Date: 11/22/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CEILING MOUNTED HEAT PUMP

SITE AND BLDG #: DE007 B-4

MECHANIC
SIGNATURE: 

DATE: 01/24/22

LOCATION/RM #:

WO# 15348

ASSET #

OY4-001-018

START TIME:

0900

FINISH TIME:

1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check fan blades for dust buildup and clean if necessary.	✓		
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	✓		
3	Tighten all electrical connectors to proper torque as needed.	✓		
4	Check contactors for compressors and fan.	✓		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓		
6	Lubricate mechanical connections of dampers sparingly as applicable.	✓		
7	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a CM Request	✓		
8	Clean coils by brushing, blowing, vacuuming	✓		
9	Use fin comb to straighten coil fins as needed.	✓		
10	Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.	✓		
11	Vacuum interior of unit.-Wipe down exterior of unit	✓		
12	Change the filter as needed with the correct size and type filter. Minimum annual Replacement.	✓		
13	Insure that drain(s) are clear and running.-Install condensate tablet	✓		
14	Clean up work area. - Record Humidity level in building	✓		Humidity %
15	Sign and date yellow maintenance tag.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: