

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 12/7/21 , 12/9/21

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S, 15217 , 15238-15242 , 15295 , 15318 , 15319 , 15384-15389 ,
2. 15494 , 15530 , 15320 , 15390-15392 , 15531 , 15393 , 15532
3. ASSET#'S, 10547-10550 , 10558 , 10612 , 10610 , 10615 , 10556 ,
4. 10557 , 10611 , 10617-10619 , 10641 , 10623 , 10624 , 10625 , 10642 ,
5. 190917-, 423 , 424 , 427 , 428 , 450 , 423-429 , 448 , 460 , 462 ,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/9/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: AMMIE MEARERO Date: 12/9/21


Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

GATES

SITE AND BLDG #: NY067 BLDG1

MECHANIC
SIGNATURE: 

DATE: 2/22/21

LOCATION/RM #: MOV PARKING

WO#

15387-

ASSET #

10617-

10619,

15389,

190917-450

START TIME: 12pm

FINISH TIME: 1pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	☒	☒	
2	Notify affected personnel before performing PM	☒	☒	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect all pivot points, hinges, latches, etc. Apply lubricant where needed, wiping off excess.	☒	☒	used PB blaster garage door lubricant
2	Check all locking devices. Lubricate as required.	☒	☒	all are good
3	Inspect gate support rollers and track, lubricate and clean as required.	☒	☒	used white lithium grease
4	Check bolts, fasteners, and mounting hardware. Tighten as necessary.	☒	☒	all are tight
5	Check for any obstructions that prevent full swing or movement of the gate.	☒	☒	no obstructions
6	Check that shrubs and trees are pruned clear of gate.	☒	☒	shrubs and trees are clear of gate
7	Check hold open devices for proper operation. Lubricate as required.	☒	☒	
8	Check the top guard and ensure that it is properly fastened and the wires are tight. Tighten as required.	☒	☒	top gaurd and wires are tight
9	If applicable, inspect hydraulic driveline (hoses, fittings, and gauges) for signs of leakage.	☒	☒	no hydraulics
10	If applicable, inspect limit switches for proper operation. Adjust as needed.	☒	☒	limit switches are correct
11	If applicable, inspect photoeyes for proper operation and any signs of damage.	☒	☒	no sign's of damage
12	If applicable, have site personnel operate gate with CAC Card insuring proper operation.	☒	☒	gate functions properly with card
13	If applicable, clean control cabinent, ensuring free from debris and insects.	☒	☒	no debris or insects

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: