

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 12/8/21-12/13/21

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15219 , 15506 , 15534 , 15220 , 15495 , 15507 , 15535 ,
2. ASSET#'S , 190917- , 606-611 , 617 , 634 , 635 , 643 , 609 , 620 ,
3. 679-681 , 691 , 695 , 698 , 705 , 706 , 724 , 697 , 699 , 701 , 704-706 ,
4. 725 , 726 ,
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/13/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LARS LUFFMAN Date: 12/13/21

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: **NY127 BLDG2**LOCATION/RM #: **work bay** WO# **15507** ASSET # **190917-697**MECHANIC
SIGNATURE:DATE: **12/8/21**START TIME: **12:30pm**FINISH TIME: **1pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Start and stop fan with local switch	✓		switch functions properly
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.-Inspect hoses -report issues -open CM ticket	✓		use Lucas heavy duty Grease
3	Inspect, adjust belts and pulleys. Replace belt as needed.	✓		adjusted belt
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	✓		all are good
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓		no excessive noise or vibration
6	Clean fan as needed.	✓		fan is clean
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	✓		no leaks found
8	Repair as needed	✓		no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: