

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 Date of Visit: 5/10/22

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'s , 17067-17073 , 17142 , 17156 , 17173 , 17074-17076,
2. ASSET#'s , 9220 , 9222 , 9240 , 9241 , 9243-9245 ,
3. 9261-9263 , 190917-, 131 , 102 , 103 , 132 , 127 , 128
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 5/10/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:


Print Name/Rank: RON VOGT Date: 5/10/22

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **NY013 BLDG1**
 LOCATION/RM #: **BLDG1** WO# **see below** ASSET #

MECHANIC SIGNATURE:  DATE: **5/10/22**
 START TIME: **9am** FINISH TIME: **9:30am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	☒	☒	no structural defects
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	☒	☒	units function properly
3	Clean exterior with dry cloth.	☒	☒	units have been wiped down
4	For Exit lights check for proper arrow direction.	☒	☒	Arrow directions are proper
5	Make and/or recommend any needed repairs.	☒	☒	no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

Additional Notes:

WO# ASSET#'S,
 17071, 9243
 17072, 9244
 17073, 9245
 17156 190917-132