

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 5/26/22

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 16919 , 16941 , 17023 , 17024-17029 , 17132 , 17146 ,
2. 17166 , 17030-17032 , 17167 , 17033 , 17034
3. ASSET#'S , 10568 , 10612 , 10559 , 10560 , 10566 , 10567 , 10568 ,
4. 10613 , 10614 , 10551 , 10636 , 10637 , 10638 , 10643 , 10644 ,
5. 190917- , 450 , 430-433 , 446 , 449 , 455

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 5/26/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Ammie Mearero Date: 5/26/22

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
TANKS, WATER STORAGE

SITE AND BLDG #: **NY067 BLDG1**MECHANIC
SIGNATURE: DATE: **5/26/22**

MECH room

LOCATION/RM #: **WO# 17166**ASSET #**190917-446**START TIME: **1pm**FINISH TIME: **1:30pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings, manholes, and handholes for leaks, signs of corrosion, and correct as indicated.	✓		no leaks or corrosion found
2	Inspect structural supports and repair or replace damaged insulation or covering. If insulation contains asbestos and is damaged or eroded, it is considered a hazardous waste.	✓		no damaged insulation
3	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	✓		no sight glass valves and controls are good
4	Clean up work site.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
ISOLATION VALVE

SITE AND BLDG #: **NY067 BLDG1**

boiler room **LOCATION/RM #:** **WO#17166** **ASSET #:** **190917-430**

MECHANIC
SIGNATURE:

DATE:

5/26/22

START TIME: 12pm

FINISH TIME: 12:15pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect valve for damage and/or leaks.	✓	/	no damage or leaks found
2	Exercise valve (at least 2 times per year) to ensure proper function. If valve does not function properly and/or leaks, open CM ticket for repair. Note the location of the valve.	✓	/	valves have been worked

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GLYCOL TANK

SITE AND BLDG #: **NY067 BLDG1**

MECH room

LOCATION/RM #: **WO# 17166**ASSET #**190917-431**MECHANIC
SIGNATURE: DATE: **5/26/22**START TIME: **12:15pm**FINISH TIME: **12:30pm**


CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank, including fittings, gauges, structural supports, manholes, and handholes for leaks, signs of corrosion, or other defects.	✓		no signs of defects or leaks
2	Clean, test and inspect sight glasses, valves, fittings, drains, and controls.	✓		all are good
3	Check condition of agitators and/or float assemblies.	✓		assemblies are good
4	If applicable, clean strainer(s).	✓		strainer is clean
5	Clean up work site.- Report any issues	✓		no issues

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EXPANSION TANKS

SITE AND BLDG #: **NY067 BLDG1**MECHANIC
SIGNATURE: DATE: **5/26/22**LOCATION/RM #: **boiler room**WO# **17166**ASSET # **190917-432**START TIME: **12:30pm**FINISH TIME: **1pm****190917-433**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Examine exterior of tank including fittings and valves for leaks, signs of corrosion, and correct as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no sign of corrosion or leaks
2	If applicable, Check sight glass, insure level is between 1/2 and 3/4 sight glass. Correct as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no sight glass
3	If applicable, check tank pressure via schrader valve. Correct as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	pressure is correct

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.


To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **NY067 BLDG1**

LOCATION/RM #: **BLDG1** WO# **17028**, ASSET # **10613**
17029, **10614**

MECHANIC
SIGNATURE: DATE: **5/26/22**START TIME: **9:30am**FINISH TIME: **10:30am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
			TO BE PERFORMED AT EACH INSPECTION SERVICE	
1	Inspect for structural defects, note needed repairs	<input checked="" type="checkbox"/>		no structural defects
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	<input checked="" type="checkbox"/>		units function properly
3	Clean exterior with dry cloth.	<input checked="" type="checkbox"/>		units have been wiped down
4	For Exit lights check for proper arrow direction.	<input checked="" type="checkbox"/>		Arrow directions are proper
5	Make and/or recommend any needed repairs.	<input checked="" type="checkbox"/>		no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: