

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 6/6/22

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 17224 , 17256 , 17257-17259 , 17306-17310 , 17363 , 17386 ,
2. 17387 , 17452-17457 , 17561 , 17570 , 17605 , 17388 , 17458 , 17459 ,
3. 17460 , 17606 , 17461 , 17607
4. ASSET#'S , 10552-10555 , 10547-10550 , 10558 , 10612 , 10610 ,
5. 10615 , 10556 , 10557 , 10611 , 10617-10619 , 10641 , 10623-10625 ,
10642 , 190917- , 423 , 424 , 427 , 428 , 451 , 450 , 423-429 , 448 , 460 ,
462

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 6/6/22

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Ammie Mearero Date: 6/6/22

Signed: _____

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: NY067 BLDG1

MECHANIC
SIGNATURE: 

DATE: 6/6/22

LOCATION/RM #: BLDG1 WO# 17306-17310

START TIME: 8:30am

FINISH TIME: 9:30am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	☒	☒	
2	Initial and Date Filter (if disposable)	☒	☒	
3	Initial and Date Yellow Maintenance Tag (if applicable)	☒	☒	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
10547	20x20x2 - 20x24x2	6-9		
10548	20x24x2	6		
10549	12x24x2 - 24x24x2	3-3		
10550	20x20x2-24x20x2-12x24x2	6-2-3		
10558	20x20x2	6		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: