CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 Date of Visit: 5/31/22

Contractor Personnel on Site:

1. Patrick Brown
2. _____
3. _____
4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 17273 , 17323-17325 , 17501 , 17502 , 17557 ,
2. 17566 , 17573 , 17583 , 17392 , 17503 , 17558 , 17584
3. ASSET#'S , 9212 , 9209 , 9210 , 9211 , 9213 , 9242 ,
4. 9265 , 9250 , 190917- , 101 , 135 , 131 , 133 , 134 , 129 ,
5. 130 , 136 , 137 , 143 ,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 5/31/22

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: RON VOGT Date: 5/31/22

Signed: _____

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FILTER REPLACEMENT

SITE AND BLDG #: NY013 BLDG1

MECHANIC SIGNATURE:

DATE: 5/31/22

LOCATION/RM #: BLDG1 **WO#** 17323-17325

START TIME: 8am **FINISH TIME:** 9am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES	TASK COMPLETE NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.			
2	Initial and Date Filter (if disposable)			
3	Initial and Date Yellow Maintenance Tag (if applicable)			

ASSET #	SIZE	QTY	NOTES/ ACTIONS
	Record Size :		
9209	20x25x2 - 16x25x2	2-4	
9210	16x25x2 - 20x25x2	2-1	
9211	16x20x2	4	
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly		
	All other filters get replaced annually But inspected Quarterly		

Note: The technician shall perform any repairs identified during PM up to $250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding $250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Technician
Additional Notes: