

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY127 Date of Visit: 6/1/22

Contractor Personnel on Site:

1. PATRICK BROWN 3. \_\_\_\_\_  
2. \_\_\_\_\_ 4. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 17226 , 17563 , 17575 , 17609 , 17227 , 17564 , 17571 , 17576 , 17610 , 17611
2. ASSET#'S , 190917- , 606-611 , 617 , 634 , 635 , 604 , 618 , 619 , 643 , 609 , 610 , 611 , 620 , 641 , 679 , 680 , 681 , 691 , 695 , 698 , 705 , 706 , 690 , 696 , 713 , 724 , 697 , 699 , 701 , 704 , 725 , 726 , 730

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 6/1/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LARS LUFFMAN Date: 6/1/22

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**FAN COIL UNIT**

SITE AND BLDG #: **NY127 BLDG1**MECHANIC  
SIGNATURE:DATE: **6/1/22**LOCATION/RM #: **BLDG1** WO# **17609****190917-609-611**  
ASSET #START TIME: **10am**FINISH TIME: **10:30am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check fan blades for dust buildup and clean if necessary.	✓		fan blades are clean
2	Check fan blades and moving parts for cracks and excessive wear.	✓		no cracks found no excessive wear
3	Tighten all electrical connectors to proper torque as needed.	✓		electrical connections are tight
4	Check that the fan runs properly in all speeds as applicable.	✓		fan runs properly in all settings
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓		all are good
7	Lubricate mechanical connections of dampers sparingly as applicable.	✓		used white lithium grease
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a CM.	✓		no signs of leaks
9	Clean coils by brushing, blowing, vacuuming	✓		coils are clean
10	Check coils for leaking, tightness of fittings.	✓		no leaks found fittings are tight
11	Use fin comb to straighten coil fins as needed.	✓		fins are straight
12	Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.	✓		no belts
13	Check rigid couplings for alignment on direct drives, and for tightness of assembly	✓		direct drives assemblies are tight
14	Vacuum interior of unit.	✓		Interiors of units are clean
15	Check filter door for proper gasketing and air leaks. Correct as needed.	✓		no air leaks found
16	Change the filter as needed with the correct size and type filter.	✓		Filter gets checked Quarterly
17	Insure that drain(s) are clear and running. - Install condensate tablet	✓		drains are clear
18	Clean up work area. - Record Humidity level in area	✓		Humidity %

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**