

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**AIR CURTAIN**

**SITE AND BLDG #:** **Rockville MD021**

**MECHANIC  
SIGNATURE:** 

**DATE:** **5/6/22**

**LOCATION/RM #:** **Bldg. 1 wo# 17688 ASSET #2107**

**START TIME:** **9:40**

**FINISH TIME:** **10:00**

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</b>
		<b>YES</b>	<b>NO</b>	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Disconnect the power to the unit.			
2	Remove the intake grille by removing all screws around the edges.			
3	Vacuum and wash (if necessary) to remove the buildup of dirt and debris.			
4	If necessary, lubricate the motors.			
5	Reinstall the cover and intake grille.			
6	Verify proper operation of unit. Make and/or recommend any needed repairs.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**