

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 1-3-19

Contractor Personnel on Site:

1. Patrick Brown 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 1716AN,1717AN,1718AN,1719AN,1720AN,1721AN,1722AN,1723AN
2. 1724AN,1725AN,1726AN,1727AN,1728AN, 1859MO
3. 1915SA,1916SA,1917SA,1918SA,1919SA,1920SA,1921SA
4. Various Kitchen Equipment, Parking Lighting, Overhead Doors, Key Card
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 1-3-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Douglas Rushko Date: 1/29/19

Signed: 

E-Mail: douglas.rushko.ctng@mail.wil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
LIGHTING, OUTSIDE

SITE AND BLDG #: NY067 - Bldg 1

LOCATION/RM #: ^{Equipment} ~~Parking~~ WO# 1859 ASSET # 10612MECHANIC
SIGNATURE: 

DATE: 1-14-19

START TIME: 12:30

FINISH TIME: 1:15

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|--|--|---------------|----|---|
| | | YES | NO | |
| 1 | In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to. | ✓ | | |
| 2 | Schedule and coordinate work with operating personnel. | ✓ | | |
| 3 | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | ✓ | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Open and tag switch. | ✓ | | |
| 2 | Inspect visual condition of wiring. Look for evidence of overheating. | ✓ | | No evidence of overheating |
| 3 | Check for proper light operation. | ✓ | | Lights operated correctly |
| 4 | Test operation of automatic switches/ time clock/ photocells if applicable. | ✓ | | |
| 5 | Inspect light pole and mounting devices for deficiencies. | ✓ | | No deficiencies found |
| 6 | For any noted deficiency, takes pictures and open corrective maintenance ticket. | ✓ | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: