

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY035 Date of Visit: 1-16-19

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 1985SA,1986SA,19687SA,1988SA,1989SA,1990SA,1991SA,1992SA,1993SA
2. Overhead Doors, Key Pad
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 1-16-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Doug Rushlo Date: 1-16-19


Signed: 

E-Mail: douglas.rushlo.tro@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
MANUAL/AUTOMATIC OVERHEAD DOORS

SITE AND BLDG #: NY 035 - Bldg 1

LOCATION/RM #:	Assembly Hall	WO#	1985	ASSET #	9856
			1987		9860
			1988		9861
			1989		9862

MECHANIC
SIGNATURE: 

DATE: 1-16-19

START TIME: 11:10

FINISH TIME: 12:45

CHECK POINT	CHECKPOINT DESCRIPTION	9863	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
SPECIAL INSTRUCTIONS					
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Check with door operating personnel for any known deficiencies.		✓		no known deficiencies
2	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.		✓		tightened Bolts on quick release arm / Emergency arm
3	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.		✓		all functions operated correctly
4	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.		✓		
5	Check manual operation. Note brake release, motor disengagement, functioning or hand pulls, chains sprockets, clutch, etc.		✓		Manual operation worked properly
6	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.		✓		all wiring is in good shape Panel is clean
7	If applicable, inspect gear box, change or add oil as required.		✓		no oil
8	Perform required lubrication. Remove old or excess lubricant.		✓		Used garage door lubricant
9	Clean unit and mechanism thoroughly. Touch up paint where required.		✓		
10	Clean up and remove all debris.		✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: