

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY035 Date of Visit: 1-16-19

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 1985SA,1986SA,19687SA,1988SA,1989SA,1990SA,1991SA,1992SA,1993SA
 2. Overhead Doors, Key Pad
 3. _____
 4. _____
 5. _____
-

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 1-16-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Doug Rushlo Date: 1-16-19

Signed: 

E-Mail: douglas.rushlo.tro@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
MANUAL/AUTOMATIC OVERHEAD DOORS

SITE AND BLDG #: N1035 - Bldg 2

 Mechanics 1991 9885
 LOCATION/RM #: Bays WO# 1992 ASSET # 9886

 MECHANIC
 SIGNATURE: 

DATE: 1-16-19

START TIME: 8:15 am

FINISH TIME: 10:30 am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check with door operating personnel for any known deficiencies.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	NO Known deficiencies
2	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Operated correctly in every position
4	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	all worked correctly
5	Check manual operation. Note brake release, motor disengagement, functioning or hand pulls, chains sprockets, clutch, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	all wiring was in good condition and tight
7	If applicable, inspect gear box, change or add oil as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	NO oil
8	Perform required lubrication. Remove old or excess lubricant.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Used garage door lubricant
9	Clean unit and mechanism thoroughly. Touch up paint where required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
10	Clean up and remove all debris.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: