

## CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 Date of Visit: 2-21-19

Contractor Personnel on Site:

1. Patrick Brown
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 2352QT, 2353QT, 2354QT, 2355QT, 2356QT, 2357QT
2. 2358QT, 2359QT, 2360QT, 2361QT
3. Refrigerator, Water heaters, Emergency Lighting
4. \_\_\_\_\_
5. \_\_\_\_\_

---

## CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 2-21-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Hutchins, Candi M. G59 Date: 20190221

Signed: 

E-Mail: candi.m.hutchins.civ@mail.mil

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**EMERGENCY EXIT SIGNS AND WALL PACKS**

ACTIVITY AND BLDG #: **NY013-02**

LOCATION/RM #: **WO# 2360 ASSET # 9262**  
**2361 9263**

MECHANIC  
SIGNATURE:

DATE: **2-21-19**

START TIME: **11 am**

FINISH TIME: **11:30 am**

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</b>
		<b>YES</b>	<b>NO</b>	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Inspect for structural defects, note needed repairs	✓		<i>no defects</i>
2	Push test buttons and observe light operation. Note any units that do not operate properly.	✓		<i>all work</i>
3	Clean exterior with dry cloth.	✓		
4	For Exit lights check for proper arrow direction.	✓		<i>arrow direction is proper</i>
5	Make and/or recommend any needed repairs.	✓		<i>no repairs needed</i>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**