

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 2-21-19

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 2208MO,2209MO,2417QT,2418QT,2419QT,2420QT, 2500SA,
2. 2421QT,2422QT,2423QT,2424QT
3. Lighting, Gate, circulating pump, Water heater, Emergency lighting,
4. Exit signs
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2-21-19

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Doug Rushlo Date: 2/22/19

Signed: _____

E-Mail: douglas.rushlo.ctr@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **EMERGENCY EXIT SIGNS AND WALL PACKS**

ACTIVITY AND BLDG #: NY039-01

MECHANIC
SIGNATURE: _____

DATE: 2-14-19

LOCATION/RM #: _____ WO# 2419 ASSET # 9933
2420 9934

START TIME: 12:30 pm

FINISH TIME: 2:30 pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	✓		No structural Defects
2	Push test buttons and observe light operation. Note any units that do not operate properly.	✓		5 wall packs need Batteries 1 wall pack needs to be replaced, 4 Exit signs need Batteries and 6 Exit signs need to be replaced
3	Clean exterior with dry cloth.	✓		
4	For Exit lights check for proper arrow direction.	✓		arrow direction on all is proper
5	Make and/or recommend any needed repairs.	✓		Email has been submitted for a cm ticket

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: