

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 2-21-19

Contractor Personnel on Site:

1. Patrick Brown 3. _____
2. _____ 4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 2208MO,2209MO,2417QT,2418QT,2419QT,2420QT, 2500SA,
2. 2421QT,2422QT,2423QT,2424QT
3. Lighting, Gate, circulating pump, Water heater, Emergency lighting,
4. Exit signs
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2-21-19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Doug Rushko Date: 2/21/19

Signed: 

E-Mail: doug.rushko.ctr@mail.mil

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **NY039-03**

MECHANIC
SIGNATURE

DATE: *2-22-19*

LOCATION/RM #:

WO# **2423/2424** ASSET # **9946/9947**

START TIME: *8: am*

FINISH TIME: *8:30 am*

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<i>✓</i>		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	<i>✓</i>		<i>bulbs need to be replaced in exit signs</i>
2	Push test buttons and observe light operation. Note any units that do not operate properly.	<i>✓</i>		
3	Clean exterior with dry cloth.	<i>✓</i>		
4	For Exit lights check for proper arrow direction.	<i>✓</i>		<i>arrow direction is proper</i>
5	Make and/or recommend any needed repairs.	<i>✓</i>		<i>and email has been submitted for a cm ticket</i>

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: