


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

FILTER REPLACEMENT

SITE AND BLDG #: NY067 bldg1
supply cage
 LOCATION/RM #: WO# 3779-3783

MECHANIC SIGNATURE:  DATE: 6/3/19
12:30pm
 START TIME: 8am FINISH TIME: 12:45:pm
10:30am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	☒	☒	
2	Initial and Date Filter (if disposable)	☒	☒	
3	Initial and Date Yellow Maintenance Tag (if applicable)	☒	☒	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
10548	20x24x2	6		
10550	20x20x2	6		
10550	24x20x2	2		
10550	12x24x2	3		
10549	12x24x2	3		
10549	24x24x2	3		
10547	20x20x2	6		
10547	20x24x2	9		
10558	20x20x2	6		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: