

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: _____ Date of Visit: _____

Contractor Personnel on Site:

- | | |
|----------|----------|
| 1. _____ | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
 2. _____
 3. _____
 4. _____
 5. _____
-

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: _____ Date: _____

Signed: 

To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: **NY051-02**MECHANIC
SIGNATURE: DATE: **6/20/19**LOCATION/RM #: **WO# 3875 ASSET # 10080**START TIME: **8am**FINISH TIME: **8:30am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Start and stop fan with local switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	switch functions properly
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no noise or vibration
3	Inspect, adjust belts and pulleys. Replace belt as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	belts and pulleys are good
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no bent blades
6	Clean fan as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	fan is clean
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no damage
8	Repair as needed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	no repairs needed

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: