

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: _____ Date of Visit: _____

Contractor Personnel on Site:

1. _____	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. _____
2. _____
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: _____ Date: _____

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: **NY039-01**MECHANIC
SIGNATURE DATE: **6/17/19**

LOCATION/RM #: Ceiling **WO#** **4084** **ASSET #** **9896**
Mounted

START TIME: **11:30am**FINISH TIME: **12:30pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	/	
2	Schedule shutdown with operating personnel, as needed.	✓	/	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check fan blades for dust buildup and clean if necessary.	✓	/	fans are clean
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	✓	/	no cracks or excessive wear
3	Tighten all electrical connectors to proper torque as needed.	✓	/	electrical connections are tight
4	Check that the fan runs properly in all speeds as applicable.	✓	/	fans run properly
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/	✓	no dampers present
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/	✓	no dampers
7	Lubricate mechanical connections of dampers sparingly as applicable.	/	✓	no dampers
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	✓	/	valve functions properly no leaks
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	✓	/	all coils are clean
10	Check coils for leaking, tightness of fittings.	✓	/	no leaks all fittings are tight
11	Use fin comb to straighten coil fins as needed.	✓	/	fins are straight
12	Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.	/	✓	no belts direct Drive
13	Check rigid couplings for alignment on direct drives, and for tightness of assembly	/	✓	no belts direct drive
14	Vacuum interior of unit.	✓	/	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
15	Check filter door for proper gasketing and air leaks. Correct as necessary.	✓	✗	no air leaks gasket are good
16	Change the filter as needed with the correct size and type filter.	✗	✓	filters will be changed when they come in
17	Insure that drain(s) are clear and running.	✗	✓	drains are clear and running
18	Clean up work area.	✗	✓	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: