

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 11/4/19

Contractor Personnel on Site:

- | | |
|-------------------------|------------|
| 1. <u>Patrick Brown</u> | 3. <u></u> |
| 2. <u></u> | 4. <u></u> |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 5749MO, 5839-5845QT, 5975PMM, 5991PMQ, 5846-5848QT,
2. 5992PMQ, 5849-5850QT
3. OUTSIDE LIGHTING, CIRCULATING PUMPS, KITCHEN EQUIP, EMERGENCY
4. LIGHTING, GATE, ISOLATION VALVES, GLYCOL FEED SYSTEM, EXP TANKS,
5. WATER HEATER, EMERGENCY LIGHTING,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 11/4/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: AMMIE Mearero Date: 11/4/19

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: NY067-01

MECHANIC
SIGNATURE: 

DATE: 11/4/19

5844 10613

LOCATION/RM #: WO# 5845 ASSET # 10614

START TIME: 9am

FINISH TIME: 11am

5991 190917-449

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	found several units that need to be repl
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	I'm requesting a CM ticket be opened
3	Clean exterior with dry cloth.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	all are clean
4	For Exit lights check for proper arrow direction.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Arrow directions are proper
5	Make and/or recommend any needed repairs.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: I found several units that need to be replaced and several units that need batteries I am requesting a CM ticket be opened