

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY067 Date of Visit: 12/20/19

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO6124-6128FQT, WO6192MO,WO6211-6222QT,WO6296-6301SA
2. WO6422PMM,WO6452PMS, WO6223QT,WO6302-6304SA, WO6453PMS
3. WO6305SA,WO6454PMS
4. FILTERS, LIGHTING,SUMP PUMP,GREASE TRAP,HEATERS,GATES
5. WALL PACKS,EXHAUST SYSTEM,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/20/19

Signed: 

To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG WILLIAM MONTES Date: 12/20/19

Signed: Will Montes

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: **NY067-02**MECHANIC
SIGNATURE DATE: **12/20/19**LOCATION/RM #: **WO# 6302 ASSET # 10623**START TIME: **1pm**FINISH TIME: **1:30pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	For gsa/oil heaters: 1. Remove access panels if applicable. 2. Check the fire box liner or refractory for cracks and leaks. 3. Check all gas lines for leaks. Repair as needed.	✓		all are good
2	Clean dirt from heater, vaccuming is preferred.	✓		unit is clean
3	Check operation of gas valve.	✓		gas valve functions properly
4	Check for gas leaks.	✓		no leaks
5	Check operation of thermostat.	✓		thermostat functions properly
6	If applicable, replace primary air intake filter.	✓		no filter
7	As needed, clean spark electrode and reset gap, replace if necessary.	✓		
8	Inspect flue pipe and connections.	✓		flue pipe is good
9	If applicable, inspect and clean outside air blower and blower intake.	✓		no outside air blower
10	Inspect unit for proper operation.	✓		unit functions properly
11	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		unit is in good condition

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: