

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 12/5/19 - 12/18/19

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO6098,6177,6178FQT, WO6210-6210MO,WO6410-6415SA,WO6420PMM
2. WO6427PMQ, WO6440PMS, WO6264QT,WO6416SA, WO6441-6442PMS
3. FILTERS, LIGHTING, GATES, HEATERS,FAN COILS,SUMP PUMP,WALL
4. PACKS, EXHAUST SYSTEM
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 12/18/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: HM1 Ernest Lovenberg Date: 12/18/19

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
SUMP PUMP

SITE AND BLDG #: **NY039-01**MECHANIC
SIGNATURE: DATE: **12/5/19**

LOCATION/RM #:

WO# 6427ASSET # **191917-264**START TIME: **7:30am**FINISH TIME: **8am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
2	Excessive sediment and debris, not removed by flushing the pit should be handled on a project basis, and not considered under this standard.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove cover plates and flush pit.	✓		
2	Inspect check valve.	✓		check valve is good
3	Inspect interior of pit for cracks.	✓		no cracks
4	Inspect cover plate is in place	✓		
5	Insuure the unit is operating properly, report any deficiencies	✓		no deficiencies
6	Clean up work area and remove all debris.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfromed by: General Maintenance Worker

Additional Notes: