

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY065 Date of Visit: 4 ~~11~~ DEC 18

Contractor Personnel on Site:

- |                      |          |
|----------------------|----------|
| 1. <u>John Daley</u> | 3. _____ |
| 2. _____             | 4. _____ |

**Work Performed:**


**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 6508 MO, 6556 QT, 6563 QT, 6725 SA
2. Single Gate Auto, Hot Water Pump, Water Tank, Grease Trap, Unit Heater, Wall Radiator
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_

**CERTIFICATION OF WORK**

To be signed by the Contractor:


Print Name: John Daley Date: 4 DEC 18

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. GRANATA Date: 4 DEC 18

Signed: 

E-Mail: \_\_\_\_\_

# **PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST** **GREASE TRAP**

SITE AND BLDG #: NY065-01

LOCATION/RM #: Kitchen WO# 6563 ASSET # 7479

MECHANIC SIGNATURE: [Signature] DATE: 4 Dec 18

START TIME: 0900 FINISH TIME: 1400

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
3	Insure proper grease disposal.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Do not use enzymes, acids, caustics, solvents or emulsifying products when cleaning or maintaining the grease traps.	✓		
2	Remove lid. If the trap is equipped with removable baffles, remove them.	✓		
3	Make sure the flow restrictor on the inflow pipe is present.	✓		
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.	✓		
5	Replace lid and baffles.	✓		
6	Return (or fill) water to grease trap	✓		
7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: