

CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA209 Date of Visit: 13 Dec 18

Contractor Personnel on Site:

1. <u>John Daley</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 6504 MO, 6519 QT, 6569 QT, 6643 SA, 6507 MO, 6808 QT, 6665 SA
2. Flood Light, Single Gate, Exp Tank, Hot Water Pump, Grease Trap, Fan Coil
3. Unit Heater, Single Gate Auto, Overhead Vehicle Exhaust, Unit Heater
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: John Daley Date: 13 Dec 18

Signed: John Daley

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: BARNES Calla S. Date: 13 Dec 18

Signed: Calla S. Barnes

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
GREASE TRAP

SITE AND BLDG #: RA 209 - 01

LOCATION/RM #: Kitchen WO# 6569 ASSET # 7485

MECHANIC
SIGNATURE:

DATE: 13 Dec 18

START TIME: 0900

FINISH TIME: 1400

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
3	Insure proper grease disposal.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Do not use enzymes, acids, caustics, solvents or emulsifying products when cleaning or maintaining the grease traps.	✓		
2	Remove lid. If the trap is equipped with removable baffles, remove them.	✓		
3	Make sure the flow restrictor on the inflow pipe is present.	✓		
4	If damages, missing parts, or cleaning is required, report them as needed to ensure proper working operation.	✓		
5	Replace lid and baffles.	✓		
6	Return (or fill) water to grease trap	✓		
7	Record grease trap maintenance activities on your log or request a receipt from your grease hauler. Keep records for 3 years.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: