

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA118 Date of Visit: ^{DEC}18 ~~11~~ 18

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>John Daley</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:


Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 6469 MO, 6529 QT, 6587 QT, 6635 SA, 6596 QT, 6680 SA
2. Flood Light, Hot Water Pump, Overhead Vehicle Exhaust, Unit Heater, Hydronic Radiator,
3. Unit Heater, Hydronic Radiator, Unit Heater, Overhead Vehicle Exhaust
4. Unit Heater,
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: John Daley Date: ^{DEC}18 ~~11~~ 18

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: LUTHER E MALORY Date: ^{DEC}18 ~~11~~ 18

Signed: 

E-Mail: _____


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **VEHICLE EXHAUST REMOVAL**

SITE AND BLDG #:

PA 118 -01

MECHANIC

SIGNATURE:



DATE: 18 Dec 18

LOCATION/RM #:

Bays

WO# 6587

ASSET #

8035
8068

START TIME:

0900

FINISH TIME:

1500

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Start and stop fan with local switch	✓		
2	Check motor and fan shaft bearings for noise, vibraton, overheating; lubrucate bearings.	✓		
3	Inspect, adjust belts and pulleys. Replace belt as needed.	✓		
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	✓		
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓		
6	Clean fan as needed.	✓		
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	✓		
8	Repair as needed	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: