

## CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA168 Date of Visit: 01 DEC 18

Contractor Personnel on Site:

- |                      |          |
|----------------------|----------|
| 1. <u>John Daley</u> | 3. _____ |
| 2. _____             | 4. _____ |

### Work Performed:

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 6495 MO, 6552 QT, 6881 SA, 6625 QT, 6679 SA,
  2. Flood Light, Double Gate, Chill Water Pump, Unit Heater Vehicle Exhaust System
  3. Unit Heater
  4. \_\_\_\_\_
  5. \_\_\_\_\_
- 

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: John Daley Date: 01 DEC 18

Signed: John Daley

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Shane Fabian / AFOS Date: 01 DEC 18

Signed: Shane Fabian

E-Mail: Shane.e.fabian.ctr@mail.mil

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VEHICLE EXHAUST REMOVAL**

SITE AND BLDG #: PA168-02

LOCATION/RM #: Bays    WO# 6625    ASSET # 8083

MECHANIC  
SIGNATURE:

DATE: 31 Dec 18

START TIME: 0830

FINISH TIME: 1530

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Start and stop fan with local switch	✓		
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	✓		
3	Inspect, adjust belts and pulleys. Replace belt as needed.	✓		
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	✓		
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	✓		
6	Clean fan as needed.	✓		
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	✓		
8	Repair as needed	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: