

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY113 Date of Visit: 2/10/20

Contractor Personnel on Site:

- |                         |          |
|-------------------------|----------|
| 1. <u>PATRICK BROWN</u> | 3. _____ |
| 2. _____                | 4. _____ |

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 6944PFA,7282PMM,7298PMQ,7314-7315 PMS,6945PFA,
2. 7286PMM, 7299PMQ, 7316-7317 PMS
3. FILTERS, GATES, EXPANSION TANKS, BYPASS FEEDER, WATER HEATERS,STORAGE
4. TANKS, EXIT SIGNS, CIRCU PUMPS, VAVs, BLDG AUTOSYSTEM, KEYPAD,
5. AIR COMPRESSOR, OUTSIDE LIGHTING,

-----

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/10/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SGT James Alsimer Date: 2/10/20

Signed: 

E-Mail: \_\_\_\_\_

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

**SITE AND BLDG #: NY113-01**

MECHANIC  
SIGNATURE \_\_\_\_\_

**DATE:** 2/10/20

**LOCATION/RM #:** **WO# 6944**

~~START TIME:~~ 8am

**FINISH TIME:** 10am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS <small>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</small>
		YES	NO	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check, clean, and/or replace filters as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Initial and Date Filter (if disposable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Initial and Date Yellow Maintenance Tag (if applicable)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
190917-502	18x10x1	34		
190917-503	20x28x1	2		
190917-504	18x10x1	22		
	<b>NOTE : Any AHU with outside air -Filter gets replaced Quarterly</b>			
	<b>All other filters get replaced annually But inspected Quarterly</b>			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

**Additional Notes:**