

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 Date of Visit: 1/8/19

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>John Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 7081 MO, 7097 SA, 7082 MO, 7098 SA, 7099 SA
2. Motor Vehicle lights, Gates, Overhead Doors, Key Pad
3. _____
4. _____
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Johnny W. Brown Date: 1/8/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Carl L. Brown Date: 20190108

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **MANUAL/AUTOMATIC OVERHEAD DOORS**

SITE AND BLDG #: DE 007 B-2MECHANIC
SIGNATURE: *[Signature]*DATE: 1/8/19LOCATION/RM #: DM5 WO# 7096 ASSET # 1798-1799START TIME: 0900FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check with door operating personnel for any known deficiencies.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Inspect general arrangement of door and mechanism, mountings, standards, wind locks, anchor bolts, counterbalances, weather stripping, door sweeps etc. Clean, tighten, and adjust repair as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	If applicable, operate with power from start to stop and at intermediate positions. Observe performance of various components, such as brake, limit switches, door operating speed, motor, gear box, etc. Clean and adjust as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Check operation of safety edges, stops, electric eye, treadle, or other operating devices. Clean and make required adjustments or repairs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>South door of Reserve side inop awaiting</i>
5	Check manual operation. Note brake release, motor disengagement, functioning or hand pulls, chains sprockets, clutch, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>approval for repairs</i>
6	If applicable, examine all wiring, motor, starter, push button, etc., blow out or vacuum if needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
7	If applicable, inspect gear box, change or add oil as required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
8	Perform required lubrication. Remove old or excess lubricant.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
9	Clean unit and mechanism thoroughly. Touch up paint where required.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
10	Clean up and remove all debris.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: