

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 2/6/20

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 6976AN, 7017-7018MO, 7208-7211QT, 7276SA, 7279PMM, 7292PMQ
2. 7304-7305 PMS, 6941PFA, 7212-7215 PMQT
3. BOILER, OUTSIDE LIGHTING, GATES, CIRCULATING PUMP, HEATER, EXPANSION
4. TANKS, EMERGENCY EXIT SIGNS, KEYPAD ENTRY, AIR COMPRESSOR FILTER
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/6/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: E5 Carlos Erazo Date: 2/6/20

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS


ACTIVITY AND BLDG #: **NY039-01**

7210 9933

LOCATION/RM #:

WO# **7211**ASSET # **9934**

7292 190917-268

MECHANIC
SIGNATURE: DATE: **2/6/20**START TIME: **10:30am**FINISH TIME: **11:30am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	✓	/	
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	✓	/	
3	Clean exterior with dry cloth.	✓	/	
4	For Exit lights check for proper arrow direction.	✓	/	arrow directions are proper
5	Make and/or recommend any needed repairs.	/	/	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: I replaced 2 exit signs and 1 wall pack