

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 2/6/20

Contractor Personnel on Site:

1. PATRICK BROWN 3. _____
2. _____ 4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO'S 6976AN, 7017-7018MO, 7208-7211QT, 7276SA, 7279PMM, 7292PMQ
2. 7304-7305 PMS, 6941PFA, 7212-7215 PMQT
3. BOILER, OUTSIDE LIGHTING, GATES, CIRCULATING PUMP, HEATER, EXPANSION
4. TANKS, EMERGENCY EXIT SIGNS, KEYPAD ENTRY, AIR COMPRESSOR FILTER
5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/6/20

Signed: 

To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: E5 Carlos Erazo Date: 2/6/20

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: **NY039-03**MECHANIC
SIGNATURE: DATE: **2/6/20**

LOCATION/RM #:	WO# 7214	ASSET # 9946
	7215	9947

START TIME: **1:15pm**FINISH TIME: **1:35pm**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs			no needed repairs
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket			units function properly
3	Clean exterior with dry cloth.			
4	For Exit lights check for proper arrow direction.			arrow directions are proper
5	Make and/or recommend any needed repairs.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: