

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 3/10/20 - 3/19/20

Contractor Personnel on Site:

1. <u>PATRICK BROWN</u>	3. _____
2. _____	4. _____

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)


1. WO'S 7357-7358FQT, 7436-7437MO, 7495-7498SA, 7653M, 7673PMS
2. 7359-7360FQT, 7464QT, 7499-7500SA
3. FILTERS, LIGHTING, GATES, AIR HANDLERS, CHILLER, MINI SPLIT, VFD,
4. HEATING AND VENT SYSTEM, PTAC, EXHAUST
5. \_\_\_\_\_

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:


Print Name: Patrick Brown Date: 3/19/20

Signed: 

To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ERIC ABBOT Date: 3/19/20

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DUCTLESS MINI SPLIT**

SITE AND BLDG #: **NY051-01**MECHANIC  
SIGNATURE: DATE: **3/19/20**LOCATION/RM #: **WO# 7498** ASSET # **10046**START TIME: **11am**FINISH TIME: **11:45am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check fan blades for dust buildup and clean if necessary.	✓		fan blades are clean
2	Check all electrical connections	✓		electrical connections are good
3	Check that the fan runs properly in all speeds as applicable.	✓		fan functions properly
4	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary.	✓		diffusers are clean
5	Check filter door for proper gasketing and air leaks. Correct as needed.	✓		
6	Change or Clean filter as needed. Filters get checked quarterly.	✓		no filter
7	Ensure condensate pump is working properly and that the drain lines are clear.	✓		drain lines are clear
8	Clean up work area.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**