

## CERTIFICATION OF WORK PREVENTIVE MAINTENANCE

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: \_\_\_\_\_ Date of Visit: \_\_\_\_\_ **6/12/19**

Contractor Personnel on Site:

1. _____	3. _____
2. _____	4. _____

### **Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)


1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_

---

## CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Johnny W Brown Date: 6/12/19

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Christopher Huebler Date: 6/12/19

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**VEHICLE EXHAUST REMOVAL**

SITE AND BLDG #: **MD005-02**

<b>LOCATION/RM #:</b>	<b>WO#</b>	<b>ASSET #</b>	<b>1525</b>
	8930	1526	
			<b>1527</b>

MECHANIC  
SIGNATURE: 

DATE:

6/12/19

START TIME: **0900**FINISH TIME: **1630**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Start and stop fan with local switch	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Inspect, adjust belts and pulleys. Replace belt as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Clean fan as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
8	Repair as needed	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**