

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: NY001 - 02 Motor Pool

MECHANIC SIGNATURE: *Christopher N Pothier* **DATE:** 8 - 5 - 20

LOCATION/RM #: Garage **WO#** 9502 **ASSET #** 9084

START TIME: **FINISH TIME:**

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|--|--|---------------|----|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to. | X | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Inspect for structural defects, note needed repairs | X | | See Notes |
| 2 | Push test buttons and observe light operation. Note any units that do not operate properly. | X | | |
| 3 | Clean exterior with dry cloth. | X | | |
| 4 | For Exit lights check for proper arrow direction. | X | | |
| 5 | Make and/or recommend any needed repairs. | X | | See Notes |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Neither of these units function.