

**CERTIFICATION OF WORK  
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY039 Date of Visit: 8/14/20

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

**Work Performed:**

**Preventive Maintenance** - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO's 9387-9388MO,9578-9581QT,9646SA,9654-9655PMA,9674-9675PMC  
.9686PMM, 9699PMQ,9711-9712PMS,9582-9583QT,9656PMA,9584-9585QT
2. LIGHTING, GATES, CIRCLATING PUMP,EMERGENCY LIGHTING, BOILERS,  
EXP TANKS, HEATERS, KEYPAD, AIR COMPRESSOR
3. \_\_\_\_\_
4. \_\_\_\_\_
  

---

5. \_\_\_\_\_

**CERTIFICATION OF WORK**

To be signed by the Contractor:


Print Name: Patrick Brown Date: 8/14/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: RON Vogt AFOS Date: 8/14/20

Signed: 

E-Mail: \_\_\_\_\_

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**CIRCULATING AND BOOSTER PUMPS**

SITE AND BLDG #: **NY039-01**

9578	9898
LOCATION/RM #:	WO# 9646 ASSET # 9930
n 9711 190917-243 and 190917-244	

MECHANIC  
SIGNATURE: DATE: **8/14/20**START TIME: **9am**FINISH TIME: **10am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication atleast annually.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Inspect couplings and check for any pump seal leaks.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Check motor mounts and vibration pads	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Tighten all pump flanges.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Visually check pump alignment and coupling	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Inspect electrical connections	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:** there is a CM request in to have these pumps repaired / replaced