

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

UNIT HEATER, ELECTRIC

SITE AND BLDG #: WV020-01

MECHANIC
SIGNATURE: *Patricia Davis*

DATE: 20 December '18

LOCATION/RM #:

START TIME: 7:30

FINISH TIME: 3:30

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV020-01	6662	4084	PM-SA-4084	N/A	N/A	N/A	J-1502000-08 1-pc Unit Heater	N/A
WV020-01	6662	4091	PM-SA-4084	N/A	N/A	N/A	J-1502000-08 1-pc Unit Heater CUH-2	N/A
WV020-01	6662	4092	PM-SA-4084	N/A	N/A	N/A	J-1502000-08 1-pc Unit Heater CUH-3	N/A
WV020-01	6662	4217	PM-SA-4084	QMARK	MUH073	N/A	J-1502000-08 1-pc Unit Heater, Electric, Suspended	Rm 111
WV020-02	6670	4116	PM-SA-4116				J-1502000-08 1-pc Unit Heater, Electric	
WV020-02	6670	4543	PM-SA-4116	N/A	N/A	N/A	J-1502000-08 2-pc Unit Heater, Wall Mounted, Spark Resistant	Bathroom
WV020-02	6670	4544	PM-SA-4116	N/A	N/A	N/A	J-1502000-08 2-pc Unit Heater, Wall Mounted, Spark Resistant	Rm 106

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer’s recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check heater coils and associated piping for leaks or corrosion.	✓		

2	Clean heating coil. Brush vacuum where accessible.	✓		
3	Inspect wiring and electrical controls for loose connections, charred, frayed or broken insulation, evidence of short circuiting, wrong size fuses, circuit breakers, or switches, and other electrical deficiencies. Tighten any loose connections.	✓		
4	Inspect fan for bent blades, unbalance, excessive noise, and vibration.	✓		
5	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.	✓		
6	Verify proper control by modulating the thermostat through complete cycle.	✓		
7	Inspect unit for proper operation.	✓		
8	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**

