

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**

**VAULT DOOR**

**SITE AND BLDG #:** WV002-01

**LOCATION/RM#:**

**MECHANIC SIGNATURE:** *Mike Meekan* **DATE:** *22 JUL 19*  
**START TIME:** *9:00 AM* **FINISH TIME:** *10:00 AM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV002-01	9766	7898					J-1502000-55 1-pc Arms Vault room 115	

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTIONS	NOTE(S)/ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO		
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	<input checked="" type="checkbox"/>			
2	Follow lock-out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>			
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>					
1	Check alignment of dial ring with lock case; correct if necessary.	<input checked="" type="checkbox"/>			
2	Check mounting screws of dial ring and lock case; tighten them, using a thread locking compound.	<input checked="" type="checkbox"/>			
3	Look for corrosion or presence of any foreign matter that will in any manner affect the lock's proper operation.	<input checked="" type="checkbox"/>			<i>Completed by Sub.</i>
4	Look for any signs of malfunctioning or impending failure.	<input checked="" type="checkbox"/>			
5	Look for any signs of tampering, forced, or covert entry; report this to the local Security and Law Enforcement Office.	<input checked="" type="checkbox"/>			
6	Check Alignment of door with frame	<input checked="" type="checkbox"/>			<i>See Con.</i>
7	Check for difficulty in opening, closing or locking the door.	<input checked="" type="checkbox"/>			

8	Replace all defective hardware	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
---	--------------------------------	-------------------------------------	--------------------------	--------------------------

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker Additional Notes: