

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**CIRCULATING AND BOOSTER PUMPS**

**SITE AND BLDG #:** WV002-01

**MECHANIC**  
**SIGNATURE:** *Andy Bird* **DATE:** *7-11-19*

**LOCATION/RM #:**

**START TIME:** *8AM* **FINISH TIME:** *9AM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV002-01	9896	7136					J-1502000-28 2-pc Circulating Pump, Domestic Hot Water	<i>Mech room</i>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>			
3	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.	<input checked="" type="checkbox"/>			
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication at least annually.	<input checked="" type="checkbox"/>			
2	Inspect couplings and check for any pump seal leaks.	<input checked="" type="checkbox"/>			
3	Check motor mounts and vibration pads	<input checked="" type="checkbox"/>			
4	Tighten all pump flanges.	<input checked="" type="checkbox"/>			
5	Visually check pump alignment and coupling	<input checked="" type="checkbox"/>			

6	Inspect electrical connections	<input checked="" type="checkbox"/>		
---	--------------------------------	-------------------------------------	--	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

