

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DOMESTIC HOT WATER HEATER - ELECTRIC**

**SITE AND BLDG #:** WV005-01

**LOCATION/RM #:**

**MECHANIC**  
**SIGNATURE:** *Andy Rine* **DATE:** 8-27-19  
**START TIME:** 9:30AM **FINISH TIME:** 11AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV005-01	10416	7072		Navien	NR-240A	9545P12	J-1502000-27 Water Heater	mech rm 30792020

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)		
		YES	NO	SPECIAL INSTRUCTIONS		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>						
1	Attach drain hose. Drain several gallons from tank to remove sediment.	✓				
2	Manually check operation of safety valve. Check for corrosion around valve. Verify the safety valve inspection tag is in place. Ensure that no personnel are in area of relief piping discharge.	✓				
3	Check all connections - electric and water. Tighten as necessary. Ensure power is disconnected to electric heaters prior to checking connections.	✓				
4	Check operation/ setting of aqua stat. Check hot water temperature with dial thermometer, set aqua stat at minimum value required for all uses.	✓				
5	Check amperage draw of upper and lower elements and compare to name plate data.		✓	N/A		
6	Clean element contacts and check for proper closing under load.		✓	N/A		

7	Clean pump, controls, switches, and starters. Check condition of pump seal or packing and replace as required.	✓		
8	If applicable, Remove and inspect Anode, replace if necessary		✓	N/A
9	Clean up work area and remove trash.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

