

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **LIGHTING, OUTSIDE**

SITE AND BLDG #: WV005-02

MECHANIC SIGNATURE: *Andy Bird*

DATE: *5-29-19*

LOCATION/RM #:

START TIME: *7:30 PM*

FINISH TIME: *8:45 PM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV005-02	8584	7444	PM-MO-7444	<i>n/a</i>			J-1502000-45 3-pc Double Light, Pole Mounted Aluminum	<i>Motor Pool</i>
WV005-02	8584	7474	PM-MO-7444	<i>n/a</i>			J-1502000-45 9-pc Flood Light, Pole Mounted Aluminum	<i>Motor Pool</i>

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule and coordinate work with operating personnel.	✓		
3	Follow lock out/tag out procedures always. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	n/a
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Open and tag switch.		✓	n/a
2	Inspect visual condition of wiring. Look for evidence of overheating.		✓	n/a
3	Check for proper light operation.		✓	n/a
4	Test operation of automatic switches/ time clock/ photocells if applicable.		✓	n/a
5	Inspect light pole and mounting devices for deficiencies.		✓	n/a

6	For any noted deficiency, takes pictures and open corrective maintenance ticket.	✓		
---	--	---	--	--

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**



No access for
nighttime.