

## PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

### ICE MAKER

MECHANIC

*Andy Bibb*

5-28-19

SITE AND BLDG #: # Y33904#

SIGNATURE:

DATE:

LOCATION/RM #:

START TIME: 10AM

FINISH TIME: 10:30AM

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV006-01	8648	6833	PM-QT-6833	<i>Hoshizaki</i>	CU3030MA-1A	11051000000000	J-1502000-23 1- pc Ice Maker, Hotel/Motel Machine w/ St orage Bin   Annual Filter PM	Rm 166

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Review manufacturer's instructions.	✓		
2	De-energize, lock out, and tag electrical circuits.	✓		
3	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.		✓	<i>N/A</i>
4	If materials containing refrigerants are discarded, comply with EPA regulations as applicable.		✓	<i>N/A</i>
5	Only approved cleaning chemicals shall be used.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.	✓		
2	Visually check for refrigerant, oil, and water leaks.	✓		
3	Inspect ice condition/size.	✓		
4	As needed, drain and clean unit with proper ice machine cleaning solution.	✓		

5	Check date on water filter, replace as needed. Water filters should be changed annually at a minimum.	<input checked="" type="checkbox"/>		2-19-19
6	Check and tighten any loose screw-type electrical connections.	<input checked="" type="checkbox"/>		
7	Check all controls; adjust if necessary.	<input checked="" type="checkbox"/>		
8	Examine water connection; open and close water valve; test ice dispensing valve and (door) metering adjustment.	<input checked="" type="checkbox"/>		
9	Check and clear ice machine draining system (drain vent, strainer, trap).	<input checked="" type="checkbox"/>		
10	Examine condition of bin doors-closure, hinges, gaskets, handles and ease of slide; lubricate as required. Check storage bin condition.	<input checked="" type="checkbox"/>		
11	Clean motor, compressor, and condenser coil.	<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker **Additional Notes:**

