

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
UNIT HEATER, INFRA-RED, RADIANT, GAS

SITE AND BLDG #: WV006-02

MECHANIC
SIGNATURE: *Candy Bird*

DATE: *6-26-14*

LOCATION/RM #:

START TIME: *11:30 AM*

FINISH TIME: *2:30 PM*

Site Location	WO #	Asset #	PM #	Manufacturer	Model Number	Serial #	Asset Description	Asset Location
WV006-02	9445	4248		TRANF			J-1502000-08 1-pc Unit Heater, Gas Fired Radiant	Mech Rm
WV006-02	9445	4252		II			J-1502000-08 1-pc Unit Heater, Gas GUH-7	Mens Bay
WV006-02	9445	4281		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-1	Womens Bay
WV006-02	9445	4282		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-2	Port 5 Rm
WV006-02	9445	4283		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-4	Bay
WV006-02	9445	4284		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-6	Bay
WV006-02	9445	4285		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-9	Bay
WV006-02	9445	4317		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended EF-14	Bay
WV006-02	9445	4319		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-3	Bay
WV006-02	9445	4320		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-5	Bay
WV006-02	9445	4321		II			J-1502000-08 1-pc Unit Heater, Gas, Suspended GUH-8	Bay
WV006-02	9445	4559					J-1502000-08 3-pc Unit Heater, Gas Fired Radiant	Supply

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	For gas/oil heaters: 1. Remove access panels if applicable. 2. Check the fire box liner or refractory for cracks and leaks. 3. Check all gas lines for leaks. Repair as needed.	✓		
2	Clean dirt from heater, vacuuming is preferred.	✓		
3	Check operation of gas valve.	✓		
4	Check for gas leaks.	✓		
5	Check operation of thermostat.	✓		
6	If applicable, replace primary air intake filter.	✓		
7	As needed, clean spark electrode and reset gap, replace if necessary.	✓		
8	Inspect flue pipe and connections.	✓		
9	If applicable, inspect and clean outside air blower and blower intake.	✓		
10	Inspect unit for proper operation.	✓		
11	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: HVAC Technician **Additional Notes:**



Asset #4283 - 2nd Bay heater has cracked heat exchanger. I turned off switch on heater and tagged - Danger
Do not use!