

Date: 9/20/2023

Region: 4C
FAC ID: WV006

CSS No.: 94848
Maximo WO No.: 13849

Asset #:

Priority: 2



Original Work Request:

All PTAC units on 1st and 2nd floors of the training building have mold growing in them and need to be pulled out and cleaned

Description of Repairs Needed:

Remove units to wash and clean mold growing on them

Labor:

	Labor Hrs	Labor Rate	Total
2 Techs	18	\$ 100.00	\$ 1,800.00
			\$ -

Material List:

	Quantity	Cost	Total
Miscellaneous Cleaners/rags	1	\$ 100.00	\$ 100.00
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:

	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$1,800.00	\$100.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$1,900.00	\$228.00	\$114.00	\$2,242.00