

Date: 7-31-24

Region: 4C

CSS No.: 98452

FAC ID: WV006

Maximo WO No.: 16391

Asset #:

Priority:  2



**Original Work Request:**

Thermostat in Rm 229 is stuck on 62 degrees and won't reset. Needs to be replaced, ticket requested by CMI during work activities.

**Description of Repairs Needed:**

Replace thermostat in Rm 229

**Labor:**

	Labor Hrs	Labor Rate	Total
Tech (1)	1	\$ 100.00	\$ 100.00
			\$ -

**Material List:**

	Quantity	Cost	Total
Honeywell (TB3026B Bacnet Thermostat)	1	\$ 349.99	\$ 349.99
		\$	-
		\$	-
		\$	-
		\$	-
		\$	-
		\$	-

**Equipment List:**

	Quantity	Cost	Total
		\$	-
		\$	-
		\$	-

**PM WO History:**



**Estimate Summary:**

Labor	Material	Equipment
\$100.00	\$349.99	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$449.99	\$54.00	\$27.00	\$530.99