

Date: 7-31-24

Region: 4C
FAC ID: WV006

CSS No.: 98597
Maximo WO No.: 16395

Asset #:

Priority: 1



Original Work Request:

The air compressors in AMSA are not running, keep tripping breaker. Air compressor are detrimental to AMSA for work orders. Emergency can be delayed until first thing in the morning, unless Tech is close.

Description of Repairs Needed:

Follow up to initial investigation to address air compressor in Mechanic Shop tripping breaker. Investment is to install conduit, wiring, a breaker and wire up a phase monitor on the air compressor in the Mechanic shop and verify operations.

Labor:

	Labor Hrs	Labor Rate	Total
Tech (1)	4	\$ 138.00	\$ 552.00
Tech (2) BESCO Subcontractor	20	\$ 158.24	\$ 3,164.80

Material List:

	Quantity	Cost	Total
Square D-70 AMP Double Pole Breaker (Q0270CP)	1	\$ 479.99	\$ 479.99
Galvanized 1" conduit (70')	70	\$ 4.86	\$ 340.20
#6 THHN Stranded wire, 25'	25	\$ 7.00	\$ 175.00
ICM401A 3 PH Monitor	1	\$ 87.78	\$ 87.78
Trip Charge	20	\$ 1.75	\$ 35.00
		\$	-
		\$	-

Equipment List:

	Quantity	Cost	Total
		\$	-
		\$	-
		\$	-

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$3,716.80	\$1,117.97	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$4,834.77	\$580.17	\$290.09	\$5,705.03